



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Abraham Lincoln School
45 Forest Avenue
Bangor, ME 04401

Date Printed: 02/02/2022
Work Order #: 2201-02776
Client Job #: 45
Date Received: 01/24/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 02/02/2022
CLIENT NAME: Abraham Lincoln School

CLIENT ADDRESS: 45 Forest Avenue
 Bangor, ME 04401

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 01/24/2022 10:20AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 11° CELSIUS
CLIENT JOB #: 45

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2201-02776-001	Drinking Water Tap - Room 3	C	DWF	01/21/2022 06:03AM	7.5	ppb			DG-NH	02/01/2022 12:44AM
2201-02776-002	Drinking Water Tap - Room 6	C	DWF	01/21/2022 06:05AM	200	ppb			JLR-NH	02/01/2022 03:17PM
2201-02776-003	Drinking Water Tap - Outside Room 7	C	DWF	01/21/2022 06:07AM	13.8	ppb			DG-NH	02/01/2022 12:47AM
2201-02776-004	Drinking Water Tap - Room 8	C	DWF	01/21/2022 06:17AM	23.5	ppb			DG-NH	02/01/2022 12:51AM
2201-02776-005	Drinking Water Tap - Room 13	C	DWF	01/21/2022 06:20AM	174	ppb			JLR-NH	02/01/2022 03:20PM
2201-02776-006	Drinking Water Tap - Room 16	C	DWF	01/21/2022 06:12AM	31.1	ppb			DG-NH	02/01/2022 01:02AM
2201-02776-007	Drinking Water Tap - Outside Room 16	C	DWF	01/21/2022 06:15AM	35.0	ppb			DG-NH	02/01/2022 01:05AM
2201-02776-008	Faucet - Teacher's Lounge	C	OT	01/21/2022 06:22AM	202	ppb			DG-NH	02/01/2022 01:09AM

Rebecca L. Labranche
 Laboratory Director