



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Downeast School
100 Moosehead Blvd
Bangor, ME 04401

Date Printed: 02/02/2022
Work Order #: 2201-02770
Client Job #: 48
Date Received: 01/24/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 02/02/2022
CLIENT NAME: Downeast School
CLIENT ADDRESS: 100 Moosehead Blvd
Bangor, ME 04401
METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

DATE AND TIME RECEIVED: 01/24/2022 10:25AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 22° CELSIUS
CLIENT JOB #: 48

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2201-02770-001	Drinking Water Tap - Room A1	C	DWF	01/22/2022 05:15AM	4850	ppb			JLR-NH	02/01/2022 11:08AM
2201-02770-002	Drinking Water Tap - Room A2	C	DWF	01/22/2022 05:18AM	20.1	ppb			DG-NH	01/31/2022 11:21PM
2201-02770-003	Drinking Water Tap - Room B14	C	DWF	01/22/2022 05:21AM	78.6	ppb			DG-NH	01/31/2022 11:24PM
2201-02770-004	Drinking Water Tap - Room B16	C	DWF	01/22/2022 05:23AM	171	ppb			DG-NH	01/31/2022 11:28PM
2201-02770-005	Drinking Water Tap - Room B17	C	DWF	01/22/2022 05:26AM	81.6	ppb			DG-NH	01/31/2022 11:31PM
2201-02770-006	Drinking Water Tap - Room B18	C	DWF	01/22/2022 05:30AM	699	ppb			JLR-NH	02/01/2022 02:34PM
2201-02770-007	Drinking Water Tap - Room B19	C	DWF	01/22/2022 05:28AM	44.2	ppb			DG-NH	01/31/2022 11:35PM
2201-02770-008	Drinking Water Tap - Room C20	C	DWF	01/22/2022 05:43AM	16.6	ppb			JLR-NH	02/01/2022 02:39PM
2201-02770-009	Drinking Water Tap - Room C21	C	DWF	01/22/2022 05:45AM	105	ppb			JLR-NH	02/01/2022 02:42PM
2201-02770-010	Drinking Water Tap - Room C22	C	DWF	01/22/2022 05:55AM	11.6	ppb			JLR-NH	02/01/2022 02:45PM
2201-02770-011	Drinking Water Tap - Room C23	C	DWF	01/22/2022 05:47AM	11.1	ppb			DG-NH	01/31/2022 11:39PM
2201-02770-012	Drinking Water Tap - Room C24	C	DWF	01/22/2022 05:52AM	18.5	ppb			JLR-NH	02/01/2022 02:48PM
2201-02770-013	Drinking Water Tap - Room C25	C	DWF	01/22/2022 05:50AM	451	ppb			JLR-NH	02/01/2022 02:59PM
2201-02770-014	Drinking Water Tap - Room D5	C	DWF	01/22/2022 06:16AM	152	ppb			JLR-NH	02/01/2022 03:02PM
2201-02770-015	Drinking Water Tap - Room D6	C	DWF	01/22/2022 06:14AM	13.9	ppb			JLR-NH	02/01/2022 03:05PM

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 02/02/2022
CLIENT NAME: Downeast School
CLIENT ADDRESS: 100 Moosehead Blvd
 Bangor, ME 04401
METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

DATE AND TIME RECEIVED: 01/24/2022 10:25AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 22° CELSIUS
CLIENT JOB #: 48

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2201-02770-016	Drinking Water Tap - Room D7	C	DWF	01/22/2022 06:12AM	30.8	ppb			JLR-NH	02/01/2022 03:08PM
2201-02770-017	Drinking Water Tap - Room D8	C	DWF	01/22/2022 06:10AM	16.8	ppb			DG-NH	01/31/2022 11:42PM
2201-02770-018	Drinking Water Tap - Room D9	C	DWF	01/22/2022 06:08AM	7.1	ppb			DG-NH	01/31/2022 11:46PM
2201-02770-019	Drinking Water Tap - Room E10	C	DWF	01/22/2022 05:58AM	3.8	ppb			DG-NH	02/01/2022
2201-02770-020	Drinking Water Tap - Room E11	C	DWF	01/22/2022 06:05AM	10.0	ppb			DG-NH	02/01/2022 12:11AM
2201-02770-021	Drinking Water Tap - Room E12	C	DWF	01/22/2022 06:01AM	85.7	ppb			JLR-NH	02/01/2022 03:11PM
2201-02770-022	Drinking Water Tap - Room E13	C	DWF	01/22/2022 06:03AM	33.4	ppb			DG-NH	02/01/2022 12:15AM
2201-02770-023	Bottle Fill Station - B Wing	C	DWF	01/22/2022 05:34AM	7.5	ppb			DG-NH	02/01/2022 12:18AM
2201-02770-024	Faucet - Book Room	C	OT	01/22/2022 05:37AM	621	ppb			JLR-NH	02/01/2022 03:14PM
2201-02770-025	Kitchen-Kettle	C	OT	01/22/2022 05:11AM	5.9	ppb			DG-NH	02/01/2022 12:22AM
2201-02770-026	Faucet - Teacher's Lounge	C	OT	01/22/2022 06:20AM	5.0	ppb			DG-NH	02/01/2022 12:26AM
2201-02770-027	Kitchen - Food Prep Faucet	C	KF	01/22/2022 05:10AM	35.6	ppb			DG-NH	02/01/2022 12:29AM

Rebecca L. Labranche
 Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Downeast School
100 Moosehead Blvd
Bangor, ME 04401

Date Printed: 02/03/2022
Work Order #: 2201-03419
Client Job #: 48
Date Received: 01/27/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 02/03/2022
CLIENT NAME: Downeast School
CLIENT ADDRESS: 100 Moosehead Blvd
 Bangor, ME 04401
METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

DATE AND TIME RECEIVED: 01/27/2022 11:25AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 3° CELSIUS
CLIENT JOB #: 48

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2201-03419-001	Faucet - Nurse Station	C	OT	01/26/2022 06:08AM	19.6	ppb			JLR-NH	02/02/2022 08:24PM
2201-03419-002	Faucet - Main Office	C	OT	01/26/2022 06:06AM	120	ppb			JLR-NH	02/02/2022 08:27PM

Rebecca L. Labranche
 Laboratory Director